

Annexure-1 (Specifications for Cable)		
1	Voltage	1.1 kV
2	No. of Cores	4
3	Size of Cable	10 Sq mm
4	Conductor Material	Copper as per class-2 of IS:8130
5	Shape of Conductor	Stranded Compacted Circular
6	Insulation Material	PVC Type-A
7	Colour	Red, Yellow, Blue & black
8	Inner Sheath	FR Type
9	Armouring	Single Layer of Galvanised Steel Round Wire
10	Outer Sheath	FR Type
11	Colour of Outer Sheath	Black
12	BIS Marked	Yes
13	In addition to marking requirements as per relevant specification, sequential marking for length, size of the cable, type of the cable shall be embossed on every metre of the cable	Yes
14	Quantity	600 m (To be supplied in a single wooden drum)
15	Note:- Type test report from central government/ NABL/ILAC accredited laboratory to prove conformity to the specification for minimum and maximum ratings have to be submitted at the time of supply	

✓ Sd/-
11/05/18