

TECHNICAL SPECIFICATION**3 Phase Potential Transformer (VT)**

As per IS3156 – 1992

Type	:	VEC 133 – 05
Ratio	:	Pri / Sec – 1 6.6 / 0.11KV
	:	Pri / Sec – 2
Burden	:	VA / Phase Sec – 1 – 100
		Sec – 2 –
Accuracy	:	Sec – 1 – 1
	:	Sec – 2 –
Connection	:	Y/Y
HV Neutral	:	Unearthed
ILV	:	22 / 60KV, HSV : 7.2KV
Voltage Factor	:	1.2 Continuous
	:	1.5 for 30 Sec.
Make	:	Kappa Electricals


24.8.17